FLOOR SCHEDULE

FIRST FLOOR -	1041 sq.m / 11205 sq.ft
SECOND FLOOR -	1041 sq.m / 11205 sq.ft
THIRD FLOOR -	1041 sq.m / 11205 sq.ft

ACCOMMODATION SCHEDULE

UNIT 10 - 2 BED - 105 sq.m / 1130 sq.ft UNIT 10 - 2 BED - 93 sq.m / 1001 sq.ft UNIT 11 - 2 BED - 114 sq.m / 1227 sq.ft UNIT 12 - 3 BED - 114 sq.m / 1227 sq.ft UNIT 13 - 2 BED - 93 sq.m / 1001 sq.ft	
UNIT 11 - 2 BED - 114 sq.m / 1227 sq.ft UNIT 12 - 3 BED - 114 sq.m / 1227 sq.ft UNIT 13 - 2 BED - 93 sq.m / 1001 sq.ft	
UNIT 12 - 3 BED - 114 sq.m / 1227 sq.ft UNIT 13 - 2 BED - 93 sq.m / 1001 sq.ft	
UNIT 13 - 2 BED - 93 sq.m / 1001 sq.ft	
1114 (1007 (1	
UNIT 14 - 3 BED - 114 sq.m / 1227 sq.ft	
UNIT 15 - 3 BED - 114 sq.m / 1227 sq.ft	
UNIT 16 - 3 BED - 135 sq.m / 1453 sq.ft	
UNIT 17 - 3 BED - 105 sq.m / 1130 sq.ft	
UNIT 18 - 2 BED - 93 sq.m / 1001 sq.ft	
UNIT 19 - 2 BED - 114 sq.m / 1227 sq.ft	
UNIT 20 - 3 BED - 114 sq.m / 1227 sq.ft	
UNIT 21 - 2 BED - 93 sq.m / 1001 sq.ft	
UNIT 22 - 3 BED - 114 sq.m / 1227 sq.ft	
UNIT 23 - 3 BED - 114 sq.m / 1227 sq.ft	
UNIT 24 - 3 BED - 135 sq.m / 1453 sq.ft	
UNIT 25 - 3 BED - 105 sq.m / 1130 sq.ft	
UNIT 26 - 2 BED - 93 sq.m / 1001 sq.ft	
UNIT 27 - 2 BED - 114 sq.m / 1227 sq.ft	
UNIT 28 - 3 BED - 114 sq.m / 1227 sq.ft	
UNIT 29 - 2 BED - 93 sq.m / 1001 sq.ft	
UNIT 30 - 3 BED - 114 sq.m / 1227 sq.ft	
UNIT 31 - 3 BED - 114 sq.m / 1227 sq.ft	
UNIT 32 - 3 BED - 135 sq.m / 1453 sq.ft	



PROPOSED THIRD FLOOR PLAN SCALE 1:200



PROPOSED SECOND FLOOR PLAN SCALE 1:200



PROPOSED FIRST FLOOR PLAN SCALE 1:200

COMMERCIAL SPRINKLERS

- A commercial sprinkler system may be required to the entire building subject to fire consultants confirmation. Commercial sprinklers require substantial holding tanks that need
- to be designed into the scheme (in some situations these can be subterranean tanks). - client should appoint a qualified Fire Consultant as soon as possible to confirm requirements, spec and constraints.

BASEMENT CAR PARKS OR STORAGE

- Additional means of escape/evacuation (stairs / lifts / ramps) may be required
- subject to Fire Consultants input, allowance made by ARC are purely indicative. Mechanical &/(or) natural ventilation may be required subject to fire consultant /
- Commercial or standard sprinkler system may be required subject to fire consultants confirmation & specification (Large water holding tank maybe required in some situations can be subterranean).
- Basement structure should be considered with fire consultant & structural engineer to ensure increased fire protection due to presence or future potential of electric car charging facilities and associated increased risks.
- NOTES-PLANNING
- The contents of this drawing are copyright.
 Planning drawings are only to be used for planning purposes & no reliance on compliance with Building regulations.

rev-30-07-24

- 3. Drawings must be read as a complete pack and not individually.
- 4. Do not scale. Figured dimensions only to be used. 5. Contractors must verify all dimensions and report any discrepancies before putting work in hand or
- making any shop drawings. 6. All flat roofs to be fitted with a man safe system to satisfy CDM 2015 regulations unless written confirmation from Principle Designer/ Principle Contractor is provided to show alternative compliance
- has been sought and approved. 7. Stair design to be independently checked by stair fabricator for regs. compliance and sizing, prior to
- construction/ ordering. Dimensions to be checked before fabrication. 8. Maclennan waterproofing specialists (or similar company with relevant PI insurance) to be instructed and detail all
- basement waterproofing designs. ARC carry no responsibility or PI cover for basement designs in terms of waterproofing or structure in any way.

 9. A design and risk assessment should form part of our drawing package, if you have not received this
- from us by post, email or collection please contact us for a copy before moving forward with the project.
- 10. We take no responsibility for the depicted site ownership boundary. Clients must notify us if they feel the our plans do not accurately depict their ownership or area of control for planning purposes.
- 11. We do not take responsibility for meeting minimum space as setout in Government Technical housing standards -
- nationally described space standards document.

 12. All Cladding & building attachments externally to be all A1 fire rated.

 FIRE: We do NOT take any responsibility and do not carry any PI cover in relation to any matters relating to fire safety, Part B building regulations, BS 9991 for fire or EWS1 and drawings in no way form a fire strategy/ report. All design/ details relating to Fire Safety are shown for indicative purposes only and should be read in conjunction with the latest version of the Appointed Fire Consultant Fire Strategy Document/ Report - all information contained in such a report supersedes ARC drawings in all aspects. No assumption of any responsibility is accepted. If you are unaware
- EWS1: an independent and an appropriately qualified and insured fire consultant/engineer should be appointed by the client/contractor to ensure the finished project is compliant. Some mortgage companies require EWS1's on buildings

who the appointed fire consultant is or don't have a copy of the latest version of the report please contact arc in writing

- outside of the EWS1 standard criteria. Part B & Fire Safety: An independent and appropriately qualified fire consultant should be instructed by the client/contractor at the earliest possible point in the design process to ensure compliance with Part B & Fire safety. Please note that subject to a fire consultants confirmation/input the following points may be required in some or all areas of the building; 1) Sprinkler systems (Domestic or commercial) 2) Mechanical smoke extraction 3) Fixed shut fire safety glass 4) some sprinkler systems require large holding tanks 5) plan changes in relation to fire safety could
- Windows forming the overheating strategy with a change in floor level exceeding 600mm between inside and outside require 1.1m guarding (APD O diagram 3.1).

result in loss of salable floor area and potential requirement for additional planning applications. (this list is not

LEGEND

10m @ 1:200

schedule amended schedule amended 17.06.25 TC 17.06.25 TC 09.06.25 TC planning consultant changes Fire consultant changes 04.02.25 TC date by No. Revision.

172 CANFORD CLIFFS ROAD, POOLE, DORSET, BH13 7ES.

PROPOSED FIRST, SECOND AND THIRD FLOOR PLAN

scale AS SHOWN @ A1	checked BC						
date JUNE 2025	drawn TC / BC					2	
9491 / 703		В	С	D			
, , , , , , ,							

ARC Architecture Itd.

Chapel Studios, 14 Purewell, Christchurch, Dorset, BH23 1EP

+44 (0)1202 479919 enquiries@andersrobertscheer.co.uk www.andersrobertscheer.co.uk

